

MOUNTAIN LAKES WATER DEPARTMENT - PWSID #1425001
PERFLUORINATED CHEMICALS - PFCs

Updated 12-11-23

PERFLUORONONANOIC ACID (PFNA)
PERFLUOROCTANOIC ACID (PFOA)
PERFLUOROCTANE SULFONIC ACID (PFOS)
 All results in nanograms per liter

MCL = 13 ppt
MCL = 14 ppt
MCL = 13 ppt

TP001001 Well 5	PFNA	PFOA	PFOS
2/22/2019	0.0	4.9	0.0
5/15/2019	0.0	4.8	0.0
8/22/2019	0.0	4.2	0.0
11/27/2019	0.0	4.1	0.0
2/20/2020	0.0	3.6	0.0
5/20/2020	0.0	4.4	0.0
7/22/2020	0.0	4.6	0.0
12/2/2020	0.0	4.8	0.0
2/25/2021	0.0	4.3	0.0
2/25/2022	0.0	6.3	2.1
3/2/2023	0.0	6.5	0.0
5/25/2023	0.0	6.9	0.0
8/28/2023	0.0	6.9	2.0
11/17/2023	0.0	5.8	0.0

TP002004 Well 4	PFNA	PFOA	PFOS
2/22/2019	0.0	11.0	0.0
5/15/2019	0.0	10.0	0.0
8/22/2019	0.0	12.0	3.3
11/27/2019	0.0	7.8	0.0
2/20/2020	0.0	11.0	2.5
5/20/2020	0.0	12.0	2.7
7/22/2020	0.0	13.0	3.3
12/2/2020	0.0	14.0	3.8
2/25/2021	0.0	11.0	2.0
5/20/2021	0.0	12.0	2.4
8/25/2021	0.0	16.0	5.4
11/24/2021	0.0	13.0	3.2
2/25/2022	0.0	13.0	2.9
5/26/2022	0.0	9.7	0.0
8/23/2022	0.0	12.0	3.1
11/29/2022	0.0	15.0	3.7
2/24/2023	0.0	16.0	2.8
5/25/2023	0.0	26.0	2.7
8/28/2023	0.0	16.0	2.8
---	---	---	---

TP003007 Well 3	PFNA	PFOA	PFOS
2/22/2019	0.0	13.0	0.0
5/15/2019	0.0	12.0	0.0
8/22/2019	0.0	6.2	0.0
11/27/2019	0.0	11.0	0.0
2/20/2020	0.0	6.7	0.0
5/20/2020	0.0	6.7	0.0
7/22/2020	0.0	6.5	0.0
12/2/2020	0.0	9.7	2.3
2/25/2021	0.0	7.3	0.0
5/20/2021	0.0	12.0	2.4
8/25/2021	0.0	9.0	2.6
11/24/2021	0.0	8.9	0.0
2/25/2022	0.0	10.0	0.0
5/26/2022	0.0	9.2	0.0
8/23/2022	0.0	6.4	0.0
11/29/2022	0.0	11.0	0.0
2/24/2023	0.0	7.5	2.4
5/25/2023	0.0	9.1	0.0
8/28/2023	0.0	12.0	2.3
11/17/2023	0.0	9.1	0.0

TP007017 Well 2	PFNA	PFOA	PFOS
2/22/2019	0.0	5.7	2.9
5/15/2019	0.0	6.6	3.0
8/22/2019	0.0	7.4	2.5
11/27/2019	0.0	6.6	2.2
2/20/2020	0.0	6.1	0.0
5/20/2020	0.0	6.9	2.9
7/22/2020	0.0	8.5	0.0
12/2/2020	0.0	6.9	2.0
2/25/2021	0.0	7.0	2.5
5/20/2021	0.0	8.9	0.0
8/25/2021	0.0	7.4	2.0
11/24/2021	0.0	9.5	2.4
2/25/2022	0.0	7.5	2.0
5/26/2022	0.0	13.0	2.9
8/23/2022	0.0	10.0	0.0
11/29/2022	0.0	6.4	0.0
2/24/2023	0.0	11.0	2.6
5/25/2023	0.0	11.0	2.2
8/28/2023	0.0	11.0	2.1
11/17/2023	0.0	11.0	0.0